

12th March 2015



**Scottish  
Water**

Always serving Scotland

Mr Barry Veitch  
Formatank Ltd  
Unit 5 Dunsdale Workshops  
Dunsdale Road  
Selkirk  
TD7 5EA

**SCOTTISH WATER**  
Byelaws Department  
Daldowie  
Broomhouse  
Uddingston  
Glasgow  
G71 7RX

W: [www.scottishwater.co.uk/byelaws](http://www.scottishwater.co.uk/byelaws)

Dear Mr Leitch,

I can confirm that if you choose to use Synolite 6060 to re-line the water storage cisterns that this will comply with Scottish Water Byelaws 2014 as it currently has suitable approval from WRAS.

I have included a copy of Scottish Water Byelaws 2014 for your information/assistance.

If you require any other information/assistance please do not hesitate to get in touch.

Regards,

A handwritten signature in black ink, appearing to read 'A. Dickson', with a long, sweeping underline.

Andrew Dickson